

SECTION 08360

SECTIONAL OVERHEAD DOORS



PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Aluminum Doors
- B. Track and Framing
- C. Hardware

1.2 RELATED SECTIONS

- A. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry.
- B. Section 05500 – Metal Fabrications: - Steel framed door openings.
- C. Section 06100 – Rough Carpentry: Wood framing and blocking for door opening.
- D. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- E. Section 08710 - Door Hardware: Cylinder locks.
- F. Section 11150 - Parking Control Equipment: Remote door control.
- G. Division 16 Sections: Electrical service and connections for powered operators.

1.3 REFERENCES

- A. ASTM A 653/A 653M – Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- B. ASTM B 209/209M – Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- C. ASTM B 221/221M – Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles and Tubes.
- D. ANSI/DASMA 102.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.

Door specifications and technical data subject to change without notice.

- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
 - 4. Operation and maintenance data.
 - 5. Nameplate data and ratings for motors.
- C. Shop Drawings: Include opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.
- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors.

1.5 WIND PERFORMANCE REQUIREMENTS

- A. Design doors to withstand positive and negative wind loads as calculated in accordance with applicable governing building codes.
 - 1. Design pressure of _____ lb/sq ft (_____ kPa)

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the types of doors specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Installation to be by qualified dealer in accordance with the manufacturer's installation instructions.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

- A. Finish:
 - 1. Five year limited warranty on anodized finish

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Amarr; 165 Carriage Court, Winston-Salem, NC 27105. ASD. Tel: (800) 503-3667. Fax: (336) 251-1851. Email: Marketing@amarr.com Website: www.amarr.com.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

Door specifications and technical data subject to change without notice.

2.2 OVERHEAD DOORS - GENERAL

- A. Provide each door with door sections, brackets, tracks, counterbalance mechanisms and hardware to suit the opening and headroom available.
- B. Hardware:
 - 1. Minimum of 14 gauge galvanized steel hinges and 13 gauge galvanized steel track brackets.
 - 2. Rollers have 10 ball bearings with casehardened inner and outer races.
 - 3. Sliding end stile locking device provided with spring-loaded bolt for inside operation only.
- C. Track: 2 inches (51 mm) or 3 inches (76 mm) as required.
 - 1. Track Lift Types
 - a. Provide standard lift track as indicated.
 - b. Provide vertical lift track as indicated.
 - 1) Provide standard vertical lift track as indicated.
 - 2) Provide Rapid Install Vertical Lift Track with TrackLock installation and safety system.
 - c. Provide high lift track as indicated.
 - d. Provide follow-the- roof-pitch tracks as indicated.
 - e. Provide low headroom tracks as indicated
 - 2. Vertical Track for standard lift, vertical lift, high lift, follow-the-roof-pitch, or low headroom track options as indicated.
 - a. RA2 clip style reverse continuous angle, 2 inch vertical track 17 or 19-gauge minimum galvanized steel, inclined using adjustable track clips attached to reversed continuous wall angle to assure weather tight closure at the jambs. *(Standard 2" track option for use with steel jambs)*
 - b. CA2 clip style continuous angle, 2 inch vertical track 17 or 19-gauge minimum galvanized steel, inclined using adjustable track clips attached to continuous wall angle to assure weather tight closure at the jambs. *(2" track option for use with wood or masonry jambs)*
 - c. BM2 bracket mount with 2 inch vertical track 17 or 19-gauge minimum galvanized steel, inclined using adjustable jamb brackets to assure weather tight closure at the jambs *(2" track option for use with wood jambs)*
 - d. RB2 reverse continuous angle with offset jamb brackets, 2 inch vertical track 17 or 19-gauge minimum galvanized steel, inclined using 12-ga minimum offset jamb brackets attached to reversed continuous angle to assure weather tight closure at the jambs. *(2" track option for use with wood or masonry jambs utilizing reverse angle jamb seal)*
 - e. TR3 tapered reverse continuous angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable tapered reverse continuous angle to assure a weather tight closure at the jambs *(Standard 3 inch track option for use with steel jambs)*
 - f. TC3 continuous tapered angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable tapered angle to assure a weather tight closure at the jambs *(3" track option often used with wood or masonry jambs)*
 - g. RA3 clip style reverse continuous angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable track clips attached to reversed continuous wall angle *(3 inch track option for use with steel jambs)*
 - h. CA3 clip style continuous angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable track clips attached to reversed continuous wall angle to assure a weather tight closure at the jambs. *(3 inch track option- often used with wood or masonry jambs)*

Door specifications and technical data subject to change without notice.

- i. RB3 reverse continuous angle with offset jamb brackets, 3 inch vertical track 12-gauge minimum galvanized steel inclined using 12-ga minimum offset jamb brackets attached to reversed continuous angle to assure weather tight closure at the jambs. *(3 inch track option for use with wood or masonry jambs utilizing reverse angle jamb seal)*
 - 3. Horizontal track for standard lift, high lift, follow-the-roof-pitch, or low headroom track options as indicated.
 - a. 2 inch 16-gauge minimum galvanized steel, reinforced with 13-gauge galvanized steel angles as required by door size and weight.
 - b. 3 inch 12-gauge minimum galvanized steel, reinforced with 11-gauge galvanized steel angles
- D. Spring Counterbalance: Torsion springs for door counter-balance mounted on a continuous cross header shaft. Springs to be oil tempered, helical wound and custom computed for each door. Cable drums to be die cast aluminum. Galvanized lift cable to provide minimum safety factor of five to one. Springs to comply with ANSI/DASMA 102 as follows:
 - 1. Standard Cycle Spring: 10,000 cycles.
 - 2. High Cycle Spring: 25,000 cycles.
 - 3. High Cycle Spring: 50,000 cycles.
 - 4. High Cycle Spring: 100,000 cycles.
- E. Handle: Galvanized steel step plate/lift handle provided on inside and outside of bottom section.
- F. Lock:
 - 1. Standard interior sliding end stile lock with hole to receive padlock.
 - 2. 5 pin cylinder lock interior lock bar and outside key.
- G. Weather stripping: 3-1/2 inches (90 mm) U-shaped vinyl bottom seal in a full-length retainer built into the bottom rail of the bottom section.
- H. Weather stripping: Perimeter seal for header and jambs.
- I. Exhaust port: Installed in bottom sections. Connecting tube from vehicles by others.

2.3 ALUMINUM DOORS

- A. Amarr 3502 (formerly model 3500) commercial aluminum full view door.
 - 1. Door Size: As indicated on the Drawings.
 - 2. Door Sections: 2 inches (51 mm) thick.
 - a. Rails and stiles extruded from 6063-T6 aluminum to produce a door thickness of 2 inches (51 mm).
 - b. Center stiles to be 2-3/4 inches (70 mm).
 - c. End stiles to be 3-3/8 inches (86 mm).
 - d. Top rails to be 3-7/8 inches (98 mm).
 - e. End Stiles and steel at end hinge attachment reinforcement locations to be 14 Ga minimum combined thickness.
 - f. Intermediate rails to be 3-3/4 inches (95 mm) per pair.
 - g. Bottom rails to be 3-7/8 inches (98 mm).
 - h. All stiles and rails to be secured with 5/16 inch (8 mm) diameter through rods.
 - 3. Standard Door Finish Options:
 - a. All aluminum rails and stiles to be a Class 1 clear anodized finish.
 - 4. Glazing Panels:
 - a. Solid Panels: 0.050 inch (1.3 mm) aluminum panels sealed with glazing tape and a vinyl glazing bead.

Door specifications and technical data subject to change without notice.

- b. Glazed Panels: 1/8 inch (3.0 mm) DSB glass panels sealed with glazing tape and a vinyl glazing bead.
- c. Glazed Panels: 1/8 inch (3.0 mm) Tempered glass panels sealed with glazing tape and a vinyl glazing bead.

5. Operation

- a. Manual Operation: Pull rope.
- b. Manual Operation: Chain hoist.
- c. Electric Motor Operation: Provide UL listed electric operator, size and type as recommended by manufacturer. Operator shall meet UL325-2010 requirements for continuous monitoring of safety devices.
 - 1) Primary Monitored Entrapment Protection Entrapment Protection: *(Required for momentary contact including radio control operation)*
 - (a) Electric sensing edge monitored to meet UL 325-2010.
 - (b) Photoelectric sensors monitored to meet UL 325-2010.
 - 2) Ancillary Entrapment Protection (optional, used to supplement primary entrapment protection or basic constant-pressure-to-close):
 - 3) Pneumatic Sensing Edge up to 22'
 - 4) Retro-Reflective photo sensor
 - 5) Operator Control Mounting:
 - (a) Flush Mount
 - (b) Surface Mount
 - 6) Operator Control Operation
 - (a) Push-button operated control stations with open, close, and stop buttons.
 - (b) Key operated control stations with open, close, and stop buttons.
 - (c) Push-button and key operated control stations with open, close, and stop buttons.
 - 7) Operator Control Location
 - (a) Interior location
 - (b) Exterior location
 - (c) Both interior and exterior location
 - 8) Special Operation:
 - (a) Vehicle detector operation
 - (b) Radio control operation
 - (c) Card reader control
 - (d) Photocell operation
 - (e) Door timer operation
 - (f) Explosion and dust ignition proof control wiring

2.4 FABRICATION

A. Aluminum Doors.

- 1. Standard maximum width: Amarr 3502 (formerly Model 3500)
 - a. 12 feet 2 inches (3.7m) widths for doors with aluminum or 1/8" glass panels.
- 2. Standard maximum height: Amarr 3552 (formerly Model 3550)
 - a. 12 feet 2 inches (3.7m) heights for doors with aluminum or 1/8" glass panels.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.

Door specifications and technical data subject to change without notice.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare opening to permit correct installation of door unit to perimeter air and vapor barrier seal.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions. Doors to be interior face mounted on a prepared surface.
- B. Anchor assembly to wall construction and building framing without distortion.
- C. Securely brace door tracks suspended from structure. Secure tracks to structural members or solid backing only.
- D. Fit and align door assembly, tracks and operating hardware.
- E. Install perimeter weatherstripping.
- F. Adjust door assembly to smooth operation and in full contact with weatherstripping.

3.4 CLEANING

- A. Clean doors, frames and glass.
- B. Remove labels and visible markings.

3.5 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION