

SECTION 08360

SECTIONAL OVERHEAD DOORS



PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Aluminum Doors
- B. Track and Framing
- C. Hardware

1.2 RELATED SECTIONS

- A. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry.
- B. Section 05500 – Metal Fabrications: - Steel framed door openings.
- C. Section 06100 – Rough Carpentry: Wood framing and blocking for door opening.
- D. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- E. Section 08710 - Door Hardware: Cylinder locks.
- F. Section 11150 - Parking Control Equipment: Remote door control.
- G. Division 16 Sections: Electrical service and connections for powered operators.

1.3 REFERENCES

- A. ASTM A 653/A 653M – Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
- B. ASTM B 209/209M – Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- C. ASTM B 221/221M – Specification for Aluminum and Aluminum-Alloy Extruded Bars, Rods, Wire, Profiles and Tubes.
- D. ANSI/DASMA 102.

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.

Door specifications and technical data subject to change without notice.

- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
 - 4. Operation and maintenance data.
 - 5. Nameplate data and ratings for motors.
- C. Shop Drawings: Include opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.
- D. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors.

1.5 WIND PERFORMANCE REQUIREMENTS

- A. Design doors to withstand positive and negative wind loads as calculated in accordance with applicable governing building codes.
 - 1. Design pressure of _____ lb/sq ft (_____ kPa)

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the types of doors specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Installation to be by qualified dealer in accordance with the manufacturer's installation instructions.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened packaging until ready for installation.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

- A. Finish:
 - 1. Five year warranty

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Amarr; 165 Carriage Court, Winston-Salem, NC 27105. ASD. Tel: (800) 503-3667. Fax: (336) 251-1851. Email: Marketing@amarr.com Website: www.amarr.com.
- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

Door specifications and technical data subject to change without notice.

2.2 OVERHEAD DOORS - GENERAL

- A. Provide each door with door sections, brackets, tracks, counterbalance mechanisms and hardware to suit the opening and headroom available.
- B. Hardware:
 - 1. Minimum of 14 gauge galvanized steel hinges and 13 gauge galvanized steel track brackets.
 - 2. Rollers have 10 ball bearings with casehardened inner and outer races.
 - 3. Sliding end stile locking device provided with spring-loaded bolt for inside operation only.
 - 4. Doors 16 feet 4 inches (4978 mm) and wider provided with double end hinges and stiles and long stem rollers.
- C. Track: 3 inches (76 mm) as required.
 - 1. Track Lift Types
 - a. Provide standard lift track as indicated.
 - b. Provide vertical lift track as indicated.
 - c. Provide high lift track as indicated.
 - d. Provide follow-the- roof-pitch tracks as indicated.
 - e. Provide low headroom tracks as indicated
 - 2. Vertical Track for standard lift, vertical lift, high lift, follow-the-roof-pitch, or low headroom track options as indicated.
 - a. TC3 continuous tapered angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable tapered angle to assure a weather tight closure at the jambs (*3" track option often used with wood or masonry jambs*)
 - b. RA3 clip style reverse continuous angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable track clips attached to reversed continuous wall angle (*3 inch track option for use with steel jambs*)
 - c. CA3 clip style continuous angle, 3 inch vertical track 12-gauge minimum galvanized steel inclined using adjustable track clips attached to reversed continuous wall angle to assure a weather tight closure at the jambs. (*3 inch track option- often used with wood or masonry jambs*)
 - 3. Horizontal track for standard lift, high lift, follow-the-roof-pitch, or low headroom track options as indicated.
 - a. 3 inch 12-gauge minimum galvanized steel, reinforced with 11-gauge galvanized steel angles
- D. Spring Counterbalance: Torsion springs for door counter-balance mounted on a continuous cross header shaft. Springs to be oil tempered, helical wound and custom computed for each door. Cable drums to be die cast aluminum. Galvanized lift cable to provide minimum safety factor of five to one. Springs to comply with ANSI/DASMA 102 as follows:
 - 1. Standard Cycle Spring: 10,000 cycles.
 - 2. High Cycle Spring: 25,000 cycles.
 - 3. High Cycle Spring: 50,000 cycles.
 - 4. High Cycle Spring: 100,000 cycles.
- E. Handle: Galvanized steel step plate/lift handle provided on inside and outside of bottom section.
- F. Lock:
 - 1. Standard interior sliding end stile lock with hole to receive padlock.
 - 2. 5 pin cylinder lock interior lock bar and outside key.

Door specifications and technical data subject to change without notice.

- G. Weather stripping: 3-1/2 inches (90 mm) U-shaped vinyl bottom seal in a full-length retainer built into the bottom rail of the bottom section.
- H. Weather stripping: Perimeter seal for header and jambs.

2.3 ALUMINUM DOORS

- A. Axolotl for Amarr AX3592 commercial aluminum full view door.
 - 1. Door Size: As indicated on the Drawings.
 - 2. Door Sections: 2.25" inches (57 mm) and 2.5" (63.5mm) thick.
 - a. Rails and stiles extruded from 6063-T6 aluminum to produce a door frame thickness of 2 inches (51 mm).
 - b. Center stiles to be 2-3/4 inches (70 mm).
 - c. End stiles to be 3-3/8 inches (86 mm).
 - d. Top rails to be 3-7/8 inches (98 mm).
 - e. Intermediate rails to be 3-3/4 inches (95 mm) per pair.
 - f. Bottom rails to be 3-7/8 inches (98 mm).
 - g. All stiles and rails to be secured with 5/16 inch (8 mm) diameter through rods.
 - h. All aluminum rails and stiles to be a Class 1 black anodized finish
 - 3. Axolotl for Amarr Exterior Panel Effects and Applied Surface Options:
 - a. Doric Exterior Panel Effect
 - 1) Anthra Zinc Applied Surface
 - 2) Treasury Bronze Perl Patina Applied Surface
 - 3) Graphite Applied Surface
 - 4) Concrete Pantheon Applied Surface
 - b. Cortex Exterior Panel Effect
 - 1) Bronze Black Florentine Applied Surface
 - 2) Treasury Bronze Perl Patina Applied Surface
 - 3) Weathered Steel Applied Surface
 - 4) Aluminum Black Antique Applied Surface
 - c. Lunar Exterior Panel Effect
 - 1) Nickel Black Florentine Applied Surface
 - 2) Aluminum Black Antique Applied Surface
 - 3) Copper Brown Florentine Applied Surface
 - 4) Treasury Bronze Perl Patina Applied Surface
 - d. Smooth Exterior Panel Effect
 - 1) Anthra Zinc Nero Applied Surface
 - 2) Pewter Applied Surface
 - 3) Sentinel Copper Applied Surface
 - 4) Armory Bronze Applied Surface
 - e. Cast Exterior Panel Effect
 - 1) Weathered Steel Applied Surface
 - 2) Treasury Bronze Perl Patina Applied Surface
 - 3) Sentinel Copper Applied Surface
 - 4) Concrete Pantheon Applied Surface
 - 4. Operation
 - a. Manual Operation: Pull rope.
 - b. Manual Operation: Chain hoist.
 - c. Electric Motor Operation: Provide UL listed electric operator, size and type as recommended by manufacturer. Operator shall meet UL325-2010 requirements for continuous monitoring of safety devices.
 - 1) Primary Monitored Entrapment Protection Entrapment Protection: *(Required for momentary contact including radio control operation)*
 - (a) Electric sensing edge monitored to meet UL 325-2010.

Door specifications and technical data subject to change without notice.

- (b) Photoelectric sensors monitored to meet UL 325-2010.
- 2) Ancillary Entrapment Protection (optional, used to supplement primary entrapment protection or basic constant-pressure-to-close):
- 3) Pneumatic Sensing Edge up to 22'
- 4) Retro-Reflective photo sensor
- 5) Operator Control Mounting:
 - (a) Flush Mount
 - (b) Surface Mount
- 6) Operator Control Operation
 - (a) Push-button operated control stations with open, close, and stop buttons.
 - (b) Key operated control stations with open, close, and stop buttons.
 - (c) Push-button and key operated control stations with open, close, and stop buttons.
- 7) Operator Control Location
 - (a) Interior location
 - (b) Exterior location
 - (c) Both interior and exterior location
- 8) Special Operation:
 - (a) Vehicle detector operation
 - (b) Radio control operation
 - (c) Card reader control
 - (d) Photocell operation
 - (e) Door timer operation
 - (f) Explosion and dust ignition proof control wiring

2.4 FABRICATION

- A. AX3592 Doors.
 - 1. Standard maximum width: AX3592
 - a. 24 feet 2 inches (7.4m) widths for AX3592 doors.
 - 1) Aluminum struts (truss bars): Provide on all Amarr AX3592 doors 16 feet 4 inches (5.0m) and wider to prevent deflection of no more than 1/120 of the spanned width when in the open position
 - 2. Standard maximum height: Amarr AX3592 20 feet 1 inch height (5.5m).

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare opening to permit correct installation of door unit to perimeter air and vapor barrier seal.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions. Doors to be interior face mounted on a prepared surface.

Door specifications and technical data subject to change without notice.

- B. Anchor assembly to wall construction and building framing without distortion.
- C. Securely brace door tracks suspended from structure. Secure tracks to structural members or solid backing only.
- D. Fit and align door assembly, tracks and operating hardware.
- E. Install perimeter weatherstripping.
- F. Adjust door assembly to smooth operation and in full contact with weatherstripping.

3.4 CLEANING

- A. Clean doors, frames and glass.
- B. Remove labels and visible markings.

3.5 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

END OF SECTION